



South Carolina Department of Health
and Environmental Control

PUBLIC NOTICE

Notice # 10176-02

March 2, 2011

This notice is to inform the public that the S. C. Department of Health and Environmental Control (DHEC) is taking public comments on a Corrective Action Plan (CAP). This CAP addresses the cleanup of soil and groundwater contamination at the facility listed below. The contamination was caused by gasoline that was released from the underground storage tank system at this facility.

FACILITY: Kent's Korner #2, 102 Main St., Wagener, SC

APPLICANT: Fuss & O'Neill, 717 Lady St., Ste. E, Columbia, SC 29201 on behalf of Garvin Oil Co., PO Box 626, Wagener, SC 29164.

SUMMARY OF CAP: Petroleum and petroleum byproducts naturally break down over time through chemical, physical, and biological processes. These processes are called natural attenuation. Fuss & O'Neill has submitted a CAP proposing the use of the following technologies in addition to natural attenuation to clean up the contamination.

- SURFAC® process patented by EcoVac Services: A surfactant is added to the subsurface to mobilize petroleum. The petroleum and surfactant is subsequently removed from the ground using dual phase and multiphase extraction.

PUBLIC COMMENT PERIOD DEADLINE: The **deadline** for submitting written comments is **5 PM March 31, 2011**. Any interested person(s) may submit written comments concerning the cleanup to DHEC's Project Manager listed below. Please bring this notice to the attention of persons whom you know will be interested in this matter. Where there is a significant degree of public interest, DHEC will hold a public hearing.

Read S. Miner
SCDHEC - UST Management Division
2600 Bull Street
Columbia SC 29201
803-896-6584

CONTACT INFORMATION: For additional information, please call the Project Manager listed above. To view a copy of the CAP, contact DHEC's Freedom of Information Office at 803-898-3882.

Section 280.67 of the S.C. Underground Storage Tank Control Regulations (R.61-92) requires that any CAP prepared to meet the requirements of 280.66 be placed on notice for public comment.